

To:

James Abramenko
 Sherlock Environmental Services
 228A 12C Street North
 Lethbridge, Alberta
 T1H 2M7

EMC LAB REPORT NUMBER: A37717

Job/Project Name: U of L Sampling

Analysis Method: Polarized Light Microscopy – EPA 600

Date Received: Mar 5/18

Date Analyzed: Mar 5/18

Analyst: Chengming Li, *Analyst*

Reviewed By: Fajun Chen, Ph.D., *Laboratory Director*

Job No: SES 18488

Number of Samples: 1

Date Reported: Mar 5/18



Client's Sample ID	Lab Sample No.	Description/Location	Sample Appearance	SAMPLE COMPONENTS (%)		
				Asbestos Fibres	Non-asbestos Fibres	Non-fibrous Material
18488-75	A37717-1	D401D W. wall above radiator	Beige, joint compound	Chrysotile	1	99

Note:

1. Bulk samples are analyzed using Polarized Light Microscopy (PLM) and dispersion staining techniques. The analytical procedures are in accordance with EPA 600/R-93/116 method.
2. The results are only related to the samples analyzed. **ND** = None Detected (no asbestos fibres were observed), **NA** = Not Analyzed (analysis stopped due to a previous positive result).
3. This report may not be reproduced, except in full without the written approval of EMC Scientific Inc. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government.
4. The Alberta Regulatory Threshold for asbestos is 1%. The limit of quantification (LOQ) is 1%.